

ITTE

Quality control of routine core analysis 6406/3-1

STATOIL
EXPLORATION & PRODUCTION
LABORATORY

Oktober - 84

LAB 84.3

Den norske stats oljeselskap a.s



Classification

Requested by

Jon Hanstveit, LET - BERGEN

Subtitle

Measurement of gas permeability, helium porosity and calculation of grain density

Co-workers

Title

Quality control of routine core analysis 6406/3-1

STATOIL EXPLORATION & PRODUCTION LABORATORY

Oktober - 84

LAB 84.317

Prepared

1/11-84 | Arnt H. Gulbrandsen

A.pproved

1/11

Kåre Sørheim

Table of contents	Page
Summary	2
Introduction	3
Experimental procedures	3
Results/Discussion	4

## Summary

A routine core analysis test was performed on core samples from well 6406/3-1. The samples were previously tested by Geco A/S, Bergen. As an independent check, Lab tested 10 horizontal samples to verify Geco's data.

Our findings are:

Concerning permeability, good agreement except for samples 15, 156.

Porosity results show good agreement except for sample 15, 70, 164.

#### Introduction

The main purpose of this work was to check routine core data done by Geco A/S, Bergen. 10 horisontal plugs from well 6406/3-1 were chosen for this check.

# Expeimental procedures

Porosity measurements were made using Boyles Law helium injection method. The permeabilities were determined using dry nitrogen, and a sealing pressure of 15 bar was applied. The Klinkenberg effect was measured by the determination of the gas permeability for each sample using a minimum of 3 different values of mean pressure. Plotting K against  $\frac{1}{Pm}$  and fitting by the least squares method to the data gives a correlation factor close to 1. Equivalent liquid permeability  $K_L$  is found by reading K value at  $\frac{1}{Pm}=0$ .

## Results/Discussion

The results are given in table 1.

Permeability results show more or less good agreement with the data given by Geco A/S, except for samples 15 and 156. Having in mind the low porosity values for these samples, Lab believe permeabilities given by Geco A/S are too high. Geco should recheck these plugs.

Geco's porosity data compare well with values found by Lab, except for the samples 15, 70, 164. Generally speaking, a difference in  $\pm$  .5 porosity units is acceptable comparing porosity data run by different Lab's.

# Routine core data measured by Lab and Geco A/S, Bergen.

Pl.no.	Depth (m)	Permeab	ility (mD)	Helium	Porosity (%	Grain	density
		Lab.	GECO A/S	Lab.	GECO A/S	Lab.	GECO A/S
		Klinken	berg. corr				(g/cc)
	L		<u> </u>	<u> </u>		<u> </u>	<u> </u>
1	3783.20	1795	1573	24.5	24.8	2.66	2.65
15	88.00	.09	25	2.5	3.2	2.69	2.70
16	88.30	4.7	4.1	7.6	8.0	2.72	2.73
40	97.00	2133	2103	19.6	20.0	2.64	2.64
60	3804.00	790	734	17.9	18.2	2.64	2.65
70	07.65	228	181	15.2	15.9	2.66	2.67
110	23.00	426	414	19.8	20.0	2.65	2.65
135	31.30	64	59.1	13.3	13.7	2.68	2.69
156	38.65	.03	28	1.2	1.1	2.68	2.68
164	41.30	26.2	22.5	11.9	11.9	2.66	2.66